

Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 002512	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 11/28/2012
NAME OF PROVIDER OR SUPPLIER OAKWOOD HEALTH CAMPUS		STREET ADDRESS, CITY, STATE, ZIP CODE 1143 23RD ST TELL CITY, IN 47586		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
K 000	<p>INITIAL COMMENTS</p> <p>A Quality Assurance Walk-thru Survey was conducted by the Indiana State Department of Health.</p> <p>Survey Date: 11/28/12</p> <p>Facility Number: 002512 Provider Number: 155671 AIM Number: 200278690</p> <p>Surveyor: Lex Brashear, Life Safety Code Specialist</p> <p>At this Quality Assurance Walk-thru survey, Oakwood Health Campus was found in compliance with 410 IAC 16.2-3.1-19(ff).</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detectors in the corridors, spaces open to the corridors, and in all resident sleeping rooms. The facility has a capacity of 97 and had a census of 73 at the time of this survey.</p> <p>The facility was found in compliance with state law in regard to sprinkler coverage and smoke detector coverage.</p> <p>All areas where residents have customary access were sprinklered and all areas providing facility services were sprinklered.</p> <p>Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 11/29/12.</p>	K 000		

Indiana State Department of Health

TITLE

(X6) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

STATE FORM

6899

GM1Y21

If continuation sheet 1 of 1